Summary of Required Permits & Approvals Received Through: Planning & Construction / EHS – Fire Safety

Remember all events must first be initiated through Student Activities

ITEM	REQUIRED
Set-up Plans	- EHS - Fire Safety
Indoor Pyrotechnics/Outdoor Fireworks	 State Fire Marshal Office approval for a Pyrotechnics/Fireworks Permit EHS Fire Safety notification Facilities Operations Work Order
Open Flames (indoor)	- EHS Fire Safety approval for an Open Burn Permit
Open Fires (outdoor)	EHS Fire Safety approval for anOpen Burn Permit andFacilities Operations Work Order
Tents	 Flame retardant certification, Structural integrity certification, Planning & Construction Inspection (if size is between 125 – 899 square feet) State Tent Permit required, (if size is over 900 square feet) Refer to Event Planning / Set up Sheet (if size is < 125 square feet)
Decorations	Flame retardant certification,Structural integrity certification,Fire Safety Inspection, as determined by EHS Fire Safety
Stages, Temporary Bleachers, Grandstands, and Seating (Indoor & Outdoor)	Structural integrity certificationPlanning & Construction InspectionState Permit Requirements
Special Amusement Arrangements	State Permit RequirementsPlanning & Construction InspectionThird Party Inspections

Insurance	Certificate for pyrotechnics/fireworks,Outside groups,Events with substantial risk
Insurance Requirements	 \$1,000,000 / occurrence Commercial General Liability \$2,000,000 General Aggregate \$2,000,000 Products and Completed Operations Aggregate \$1,000,000 combined single limit Commercial Auto liability (if company vehicles are operated on campus) Workers' Compensation for all companies with three or more employees. An indemnification clause: Commonwealth /RU be named an additional insured on the policy for the specific named contract. Evidence of Pollution Liability insurance starting at \$1,000,000 for very large, complex or hazardous contracts.

Event Set – Up / Planning Checklist:

Public Assembly Event Self-Check Form Fire and Life Safety

Fire - Police - Rescue 911

RUPD Non-emergency (540) 831-5500 EHS Fire Safety – (540) 831-7792 or 7791

DATE: TIME: LOCATION:	
EVENT: PERSON DOING CHECK:	
Exit announcement read, displayed or posted? YesNo (If "no", arrange to provide the required announcement.)	
Exit doors clear and unobstructed (on both sides)? Yes No (If "no", remove the obstructions.)	
Exit paths clear and unobstructed all the way to outside? Yes No (If "no", remove the obstructions.)	
Wires taped down or otherwise secured? Yes No n/a (If "no", tape down or otherwise cover the wires.)	
Aisles clear and unobstructed? Yes No (If "no", remove the obstructions.)	
Exit lights on and unobstructed? Yes No (If "no", remove the obstructions.)	
Emergency lights unobstructed? Yes No (If "no", remove the obstructions.)	
Floor set-up approved? Yes No n/a (If "no", contact EHS immediately.)	
Fire protection equipment unobstructed? Yes No (If "no", remove the obstructions from: - Fire alarm pull stations; - Fire alarm horns, bells or speakers, and strobe lights; fire extinguishers.)	
Decorations non-flammable? Yes No n/a (If "no", remove the materials.)	
Use of open flames approved? Yes No n/a (If "no", extinguish and do not use.)	
Use of pyrotechnics approved? Yes No (If "no" - contact EHS immediately)	
Crowd managers in place?Yes No (If "no", contact EHS.) - 1 crowd manager for every 250 occupants	
Tents (< 125 square feet) are properly used? Yes No n/a - Tents should be properly erected and secured - All tent anchors and structural supports must be properly secured - Tents should be placed a minimum of 20 feet away from the buildings and structures - Tents should not be place under or close to foliage - Tents should not block any means of egress from other structures, sidewalks or emergency fire lanes	
 Tents should not block any means of egress from other structures, sidewarks of emergency fire falles A minimum of 20 feet distance should be maintained between any cooking activity / open flames and the tent 	

At least one multi-purpose (ABC) extinguisher (with minimum 4A rating) should be provided in the vicinity

Tents (over 125 square feet) have proper certification and permits if required? __ Yes __ No __ n/a

- Contact EHS Fire Safety for fire inspection prior to occupancy

- Flame retardant certification required at site

- Structural integrity

Emergency Medical Services in place? __ Yes __ No__n/a (If "no", contact the RU Rescue.)

Post-event check completed? __ Yes __ No (If "no", perform post event check.)

- Smoking materials safely extinguished (where smoking is allowed)

- Approved open flames safely extinguished

- Unnecessary electrical equipment turned off

- No obvious hazards